

Lyubomir A. Zdravkov

**INTRODUCTION IN DESIGN
OF ABOVEGROUND CYLINDRICAL
STEEL TANKS**

SUMMARY:

Introduction	4
Frequently used symbols	5
Chapter 1	
GENERAL CONDITIONS	
1.1 Purpose of tanks. Types	6
1.2 Main constructive elements of tanks	6
1.3 Methods for calculations of shell of steel vertical tanks	7
1.4 Tank' construction development in Bulgaria	8
Chapter 2	
MATERIALS	
2.1 Hot rolled sheets	9
2.2 Steel sections	12
2.3 Steel pipes.....	12
2.4 Welding materials.....	12
Chapter 3	
CHOICE OF GENERAL TANKS' DIMENSIONS	
3.1 Optimum shell height	13
3.2 Roof height	15
Chapter 4	
ROOFS OF TANKS	
4.1 Determination of the roof type	16
4.2 Design of the elements of fixed roofs	25
4.3 Efforts in top angle and determination of the geometrical characteristic in the tanks with fixed roofs	35
4.4 Efforts in the central ring of tank's roof	38
4.5 Design of the elements of floating roofs	39
Chapter 5	
SHELL OF TANKS	
5.1 Stress calculations	59
5.2 Check of the shell for stability loss	53
5.3 Minimum section modulus of the main wind girder in open above tanks	59
Chapter 6	
TANK'S BOTTOM	
6.1 Annular bottom plates	62
6.2 Central bottom plates	67
Chapter 7	
EARTHQUAKE DESIGN	
7.1 Main damages on the tanks due to seismic impact	68
7.2 Behavior of the liquid in the tank during the earthquake.....	68
7.3 Overturning moment during the earthquake	69
7.4 Horizontal efforts during the earthquake.....	71
7.5 Maximum height of liquid wave A_{kt}	71
7.6 Stability of the tank against overturning.....	72
7.7 Maximum admissible longitudinal efforts in the tank's shell	73
7.8 Stability of the tank against sliding due to the seismic impact	75

Chapter 8	
STABILITY OF THE POSITION	
8.1 Check for uplift of the tank	76
8.2 Check for overturning of the tank	77
8.3 Check for sliding of the tank	78
8.4 Necessary measurements when the some of checks does not show satisfactory results ..	78
Chapter 9	
ANCHORING OF THE TANKS	
9.1 Design of anchor bolts	79
9.2 Measurement of the anchor chair	80
9.3 Construction of the anchors	82
Chapter10	
FOUNDATION CONSTRUCTION	
10.1 Bottom section.....	83
10.2 Preliminary data for design	83
10.3 Types of foundation construction	84
Chapter 11	
CREATING AND REINFORCING OPENINGS	
11.1 Adding openings without supplementary reinforcement of the shell with sheets	88
11.2 Opening in the shell reinforced through inserted sheets	89
11.3 Opening in the shell reinforced through overlap sheets	91
Chapter 12	
PROTECTION OF STEEL TANKS AGAINST CORROSION	
12.1 Anticorrosion lining	92
12.2 Secure the reliability of construction with corrosion allowance	93
CONCLUSION	96
LITERATURE.....	97

INTRODUCTION

The current thesis examines aboveground vertical steel cylindrical tanks made by carbon or low alloy steels with volume from 100 m³ up to 100 000 m³ for water, condensate, spirits, milk, oil and oil products. The tanks have welded shell and bottom and are not used when there is an additional internal pressure more than 2,5 κPa and negative pressure (vacuum) till 0,5 κPa. Maximum design temperature of the metal does not exceed 300 °C. When the design temperature is more than 100°C the changes in mechanical properties of the steel must be considered.

The here described researches and the calculated correlations are valid for aboveground cylindrical steel vertical tanks for another stored product but are not valid for isothermal tanks and tank for storage of aggressive chemical products.

The current document generalizes the author's researches on the tank construction but also knowledge and experience of different organizations working in field of designing, execution, exploitation, inspection, repairing works and reconstruction of vertical steel cylindrical tanks.

During the preparation of the thesis, author made analysis and reported:

- accessible literature concerning the theme, as particular accent has been put on the European standards;
- experience in design, repairing works, mounting and exploitation of the tanks;
- results from the inspections of steel tanks;
- data obtained from the failures of steel tanks.

Referring the co-ordination of the Bulgarian and end European Union laws the author focused its attention on the last editions of the European standards in this field - EN 1993-4-2 и EN 14015:2004. After its admission as Bulgarian National Standards all steel tanks must be designed in accordance with its prescriptions and requirements.

On the other hand, the tanks which are in service now, are designed following another conception, standards and methodology. The author signed particular parts of them because of following reasons:

- to facilitate the transfer from the old Russian standards to new European ones;
- to compare the Russian and European methodology for tank's design and the calculated through them results;
- to aid the assessment of the conditions of tanks in service. In order to make a correct assessment of the real conditions of tanks and internal processes, we need to know design basis, rules and tradition according to which the tanks have been designed.

A minimum of requirements for safety and constructive integrity of new built tanks have been mentioned in this thesis. The mentioned here requirements are limited to the following elements:

Foundation construction, bottom, shell, roof, stair, platforms and handrails, attached assistant technological equipment and nozzles till faces of first flange.

The shared here ideas and scientific researches, obtained results and analyses can help the students specialty "Structural Engineering" in UACG, Sofia as well as the organization which:

- prepare documentations for design of new built tanks;
- produce and/or mount tank's construction;
- prepare documentations for design or repairing works, changes and reconstruction of the tanks;
- execute repairing works, changes and reconstruction of the tanks in service.

CONCLUSION

The steel tanks are engineer facilities which must be safety and reliable, and which work almost incessantly under maximum exploitation loads. The destruction of such a facility brings big material, ecological, technological and financial loss. Due to this reason to guarantee more safety of products storage and to prevent failures is a trend in all developed countries.

The intensive development of tank's construction in Bulgaria and abroad, and experience gained from tanks failure, help us to make a conclusion that tanks designed and constructed according to increased requirements for their endurance and exploitation safety are not perfect and supplementary researches are needed in the stages of design, construction and exploitation.

The tanks designed according to the last achievement of science and practice can be damaged and can be destructed due to action or the lack of action during the exploitation.

To increase tank safety we need to undertake different by their type but connected between themselves organizational, technological, constructive and chemical activities

To assure the steel tanks reliability during their exploitation is connected with:

- incessant extension of knowledge for real work of sheets construction and introducing the last achievement of science and practice;
- control on the quality of producing and mounting operations, necessary for tanks building;
- the devices mounted on the tanks must have high level of precision and safety;
- periodical activities for outside, partial and entire tanks inspection for assessment of their real condition;
- expert assessment of the results obtained during the inspection;
- determination of remaining resource and admissible regime of exploitation of steel vertical tanks;
- execution of necessary repairing works of tanks or stop their exploitation if necessary;
- incessant training of all participants in design, producing, mounting, exploitation, inspection and repairing works of the tanks .

LITERATURE

1. Technical literature

1. БАРЗОВ П., Коррозия на вътрешната повърхност на стоманените резервоари за нефтопродукти, Нефт и химия, 1, 1981.
2. БЕЛЕНЯ Е. И., Металлические конструкции, Москва, 1986.
3. БЕЛОЕВ М. Г. и др., Некоторые проблемы при строительстве резервуаров, Доклад, Научна конференция, Киев, 1998.
4. БЕРЕЗИН В. Л., ШУТОВ В. Е., Прочность и устойчивость резервуаров и трубопроводов, Недра, 1973.
5. БОРДОВСКИЙ А. М., Медник Б. М., и др. Тенденции в развитии комплексных требований к резервуарам для хранения нефти (зарубежный опыт), Основа, 2000.
6. ВЕНКОВ Л. В., Вертикални цилиндрични резервоари. Ръководство за курсово проектиране, ВИАС, 1987.
7. ВЪРБАНОВ Х., Тепавичаров А., Ганев Т., Приложна теория на еластичността и пластичността, Техника, 1992.
8. ЗДРАВКОВ Л. А., Повишаване на сигурността на стоманени вертикални цилиндрични резервоари, намиращи се в експлоатация, Дисертация, УАСГ, 2005.
9. КОРНИЕНКО В. С., ПОПОВСКИЙ Б. В., Сооружения резервуаров, 1971.
10. КОСТАДИНОВ Й. К., СТАНЧЕВ С., Опитът на КЗУ при производство на резервоари по рулонен метод, 1976.
11. ЛЕССИГ Е. Н. и др., Листовые металлические конструкции, Москва, 1970.
12. МЕЛЬНИКОВ Н. П. и др., Металлические конструкции, Справочник проектировщика, 1980.
13. ПОПОВСКИЙ Б. В. и др., Сооружение газохранилищ и нефтебаз, Недра, 1973.
14. РАЕВСКИЙ Г. В., Некоторые вопросы проектирования стальных резервуаров большой емкости, Стройиздат, 1968.
15. РУСЕВ С. С., ЗАХАРИЕВА Н., Върху корозионната устойчивост на стоманените мазутни резервоари, сп. Строителство, кн. 1, 1977.
16. РУСЕВ С. С., Изчисляване на стоманени вертикални цилиндрични резервоари на сеизмични въздействия според нормативните методики, сп. Строителство, кн. 6, 1988.
17. РУСЕВ С. С., Здравков Л. А., Допълнителни конструктивни решения за еднопалубни плаващи покриви при голямогабаритни резервоари, конференция на IASS, Варна, 2006.
18. САФАРЯН М. К., Современное состояние резервуаростроения и перспективы его развития, 1972.
19. САФАРЯН М. К., Металлические резервуары и газгольдеры, Недра, 1987.
20. BELLUZIO, *Scienza delle costruzioni*, Bologna, 1954.
21. BROWNELL L. E., YOUNG E. H., *Process Equipment Design*, New York – London, 1968.
22. Environmental Regulations Drive Changes in Floating-Roof Designs for Storage Tanks, *Modern Bulk Transporter*, May 1, 2001.
23. GALLAGHER Terry, *Floating Roof Tank Design and Operation in the Petroleum Industry*, Chicago Bridge & Iron Company, 2000.
24. HINER Larry, Soules J. G., Cooperman Alex, *An Overview of Seismic Analysis of Large Storage Tanks*, Chicago Bridge & Iron Company, 1999.
25. MANOS George, Evaluation of the Earthquake Performance of Anchored Wine Tanks During the San Juan, Argentina, 1977 Earthquake, *Earthquake Engineering and Structural Dynamics*, Vol. 20, 1991.
26. MYERS P. E., *Aboveground Storage Tanks*, McGraw-Hill, 1997.
27. PEEK R., JENNINGS P. C., *Simplified Analysis of unanchored Tanks*, *Earthquake Engineering and Structural Dynamics*, 1988.
28. WOZNIAK R. S. and Mitchell W. W., *Basis of Seismic Design Provisions for Welded Oil Storage Tanks*, American Petroleum Institute, Washington D. C., 1978.
29. ZIOLKO J., *Zbiorniki metalowe na ciecze i gazy*, Arkady, Warszawa, 1986.

2. Normative documents and standards

30. Инструкция за изготвяне и технология на монтажа и заваряването на СВР с обем от 100 до 10 000 м³ за системата на енергетиката, Енергопроект, 1995.
31. Инструкция за проектиране на СВЦР с обем от 100 до 10 000 м³ за системата на енергетиката, Енергопроект, 1995.
32. Инструкция по проектированию, изготовлению и монтажу вертикальных цилиндрических стальных резервуаров для нефти и нефтепродукты, Нормы Республика Казахстан, 01.01.2005.
33. НАРЕДБА №3 за основните положения за проектиране на конструкции на строежите и въздействията върху тях, ДВ, бр. 92 от 2004
34. НАРЕДБА №2 за проектиране на сгради и съоръжения в земетръсни райони, ДВ, бр. 68 от 2007 г
35. Норми за проектиране на стоманени конструкции, КТСУ, 1986.
36. Нормы проектирования стальных вертикальных резервуаров для хранения нефти объемом 1000 – 50 000 куб. м, РД 16.01 – 60.30.00 – КТН 026 – 1 – 04, Москва, 2004.
37. Правила устройства вертикальных цилиндрических стальных резервуаров для нефти и нефтепродуктов, ПБ 03-381-00, 2000.
38. Рекомендации по расчету стальных вертикальных цилиндрических резервуаров на сейсмические воздействия, ЦНИИСК, 1994.
39. Ръководство за проектиране на СВР, БРВ – КЗР, 1988.
40. Сооружения промышленных предприятий, СНиП 2.09.03, 1985.
41. Типова работна документация на СВР с обем от 100 до 10 000 м³, изградени по рулонен метод, МССМ, 1977.
42. API Std 650, Welded Steel Tanks for Oil Storage, Tenth Edition, Addendum 1÷4, December 2005.
43. API Std 653, Tank Inspection, Repair, Alteration and Reconstruction, 2001.
44. BS 2654:1989, Manufacture of vertical steel welded non-refrigerated storage tanks with but – welded shells for the petroleum industry.
45. DIN 4119, Oherirdische zylindrische Flachboden Tank, bauwerke aus metalischen Werkstoffen, 1980.
46. ENV 1993-1-6: Design of Steel Structures, Part 1-6: General rules: Supplementary Rules for the Strength and Stability of Shell Structures, March 1998.
47. EN 1993-4-2: Design of Steel Structures, Part 4-2: Tanks, February 2007.
48. EN 14015:2004, Specification for the design and manufacture of site built, vertical, cylindrical, flat-bottomed, above ground, welded, steel tanks for the storage of liquids at ambient temperature and above, November 2004.